

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. DWSD/25-26/11Dated: 23-06-2025

It is certified that an inspection team headed by B. K. PRASAD; TECHNICAL MANAGER
 (Name of Officers with designation) from D.W. & S. DIVISION, HAZARIBAG
 (Name of Department/ Office) inspected the SRIDAS INTERNATIONAL SCHOOL, HAZARIBAG
 (Name & Address of the school) on 21-06-2025 (date of inspection) and found that
 the SRIDAS INTERNATIONAL SCHOOL (Name of school) has safe drinking water facilities
 for the students and members of staff of the institution and is maintaining the hygienic sanitation
 condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
 The above is valid for a period of 22-12-2025 (06 Month)

Signature with Seal: [Signature]
23/06/2025

Name

Designation

Name & Address of the Office / Department : [Signature]
23/6/25

To

SRIDAS INTERNATIONAL SCHOOLDEOCHANDA MORE, BARAHI
HAZARIBAG

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English.. If it is issued in vernacular language,
 translated notarized version in English be uploaded along with the original vernacular certificate as a
 single pdf.



District Level Water Testing Laboratory, Hazaribagh

Test Report

Report No:216	Group :- Water SRIDAF INTERNATIONAL SCHOOL, DEOCHANDA MORE,KHORAIAR, BARIH, HAZARIBAGH	Report Issue Date : 23.06.2025	
Discipline:- Chemical		Sub -Group: Drinking Water	
Issued To:		SAMPLE CODE:- 5	
Sample Description / Type	G.W (Drinking Water)	Sample Provided by	Lab Rep Sujit Kumar
Sample Location	FINAL OUTLET	Sample Quantity / Packing	2 L PVC Bottle
Date of Sample Received	21.06.2025	Temperature	25±2°C
Date of start of Analysis	21.06.2025	Humidity	50±15 % RH
Date of Completion Analysis :	23.06.2025		N/A
ULR No-	N/A		



Test Result

Sl. No.	Parameter	Unit	Result	Method Reference	Specification as per BIS – 10500:2012 (Second Revision) Amendment – June 2015	
					Acceptable Limit (Max)	Permissible Limit (In Absence of Alternate source) (Max)
(A)	CHEMICAL PARAMETERS					
1	pH	-	6.65	APIHA 23 rd Edition 2017-4500-II* B, (Electrometric Method)	6.5 – 8.5	No relaxation
2	Turbidity	NTU	3.5	APIHA-23 rd Edition 2017-2130-A, (Nephelometric method)	1	5
3	Chloride (as Cl)	mg/L, Max	20	APIHA-23 rd Edition 2017-4500- B, (Argentometric method)	250	1000
4	Total Hardness as CaCO ₃	mg/L, Max	180	APIHA-23 rd Edition 2017-2340-C (EDTA Titrimetric method)	200	600
5	Total Alkalinity as CaCO ₃	mg/L, Max	210	APIHA-23 rd Edition 2017-2320-B, (Titration Method)	200	600
6	Calcium as Ca ⁺	mg/L, Max	64.14	APIHA-23 rd Edition 2017-3500-Ca-D, (EDTA Titrimetric Method)	75	200
7	Magnesium as Mg ⁺	mg/L, Max	05.95	APIHA-23 rd Edition 2017-3500-Mg-D, (EDTA Titrimetric Method)	30	100
8	Fluoride as F	mg/L, Max	0.18	APIHA 23 rd Ed. 2017-4500 F ⁻ C, (Ion selective electrode method)	1.0	1.50
9	Colour	CU (Hazen)	2	APIHA 23 rd Edition (Visual Comparison Method)	5	15
10	Odour	-	Agreeable	IS 3025 (Part-5)	Agreeable	Agreeable
(B)	BIOLOGICAL PARAMETERS					
11	Total Coliform	CFU/100 mL	0	APIHA 23 rd Ed. 2017-9222B (Membrane Filter Technique)	Shall not be detectable in any 100 mL Sample	
12	Thermotolerant(Fecal) Coliform/ E.Coli	CFU/100 mL	0	APIHA 23 rd Ed. 2017-9222D (Membrane Filter Technique)	Shall not be detectable in any 100 mL Sample	

Remarks:- According to above parameters Water is fit for drinking Yes (✓) / No ()

Specific contractual notes:-

1. The results listed refer only to the tested sample and applicable parameter.
2. This report shall not be reproduced except in full without approval of the laboratory.
3. This report results apply to the sample as received.
4. This report results relate only to the items tested.
5. This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
6. Tested Sample shall be retained up to seven days from the date of issue of the test report
7. The liability of the laboratory is limited to the invoiced amount.
8. All disputes are subjected to the Hazaribagh Jurisdiction.
9. NOTE:- BDL=Below Detection Limit

Reviewed by	Authorized by
 23/06/2025	 23/06/2025
Mr. B.K. Prasad	Quality Manager
Technical Manager	

End of Report.....

Address:- Office of the Executive, Engineer, Drinking Water and Sanitation Division, Hazaribagh
Contact no-7004844353. Email: dlwtl.hazaribagh@gmail.com